

2430 "E" Street N. W.
Washington, D. C.
15 September 1953

25X1A9a



Flush Wood Doors

25X1A9a

Dear Mr. [REDACTED]:


Reference is made to your letter of 8 September 1953, same subject.

While the standard (PBS) specification upon which Paragraph 28.77 of our specifications was based actually calls for 1/8-inch thick veneer before sanding, it is believed that the intent is to accept the standard of the National Woodwork Manufacturer's Association, i.e., that "in no event shall combined thickness of face veneer and crossbanding before sanding be less than 1/8 inch thick."

You are hereby authorized to accept doors which will meet the above requirement.

Very truly yours,

25X1A9a



P. S. Attached is copy of the Bureau of Standards publication previously mentioned. It was my impression that you had requested a copy of it and that an additional copy had been received and retained here.